



A P P R O V A L S ®

Certificate of Conformity

Certificate No.: SAA-181240-EA

Certificate Holder: Zhejiang Benyi Electrical Co., Ltd.
Wenzhou Bridge Industrial Zone,
Beibaixiang, Yueqing,
Zhejiang 325603
P.R. China

Class Description: DC Isolator
Product Description: PV Switch Disconnecter
Brand Name: ZJBENY
Model No.: BYH-32
Markings: 1000Vdc ($I_e=13, 32A$),
800Vdc ($I_e=32, 45A$),
600Vdc ($I_e=32, 50A$)
Ta: -40°C to +85°C, DC-PV2, IP66NW
Standard: AS 60947.3:2018
AS/NZS IEC 60947.1:2015
Conditions: Nil
Approval Mark: RCM and SAA-181240-EA
Date First Registered: 6 July 2018
Date of Expiry: 6 July 2023

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 06-07-18 181240/1a
Correction to Standard

www.jas-anz.org/register



Certificate of Conformity

Addendum

Certificate No.: SAA-181240-EA

Date of Issue: 13 November 2018

Class Description: DC Isolator

Product Description: PV Switch Disconnecter

General Modification:

Rating reduced from:

1000Vdc (Ie=13, 32A), 800Vdc (Ie=32, 45A), 600Vdc (Ie=32, 50A); to

1000Vdc (Ie=9, 32A), 800Vdc (Ie=32A), 600Vdc (Ie=13, 32A), 500Vdc (Ie=32, 40A), 300Vdc (Ie=32, 40A).

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 13-11-18 181240/3



APPROVALS®

Certificate of Conformity

Addendum

Certificate No.: SAA-181240-EA

Date of Issue: 6 July 2018

Class Description: DC Isolator

Product Description: PV Switch Disconnecter

Additional Models

BYH-32M1

BYH-32M2

Description

Similar to BYH-32 except with PV-connector common MC4.

Similar to BYH-32M1 except with PV-connector genuine MC4.

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 06-07-18 181240/2