



A P P R O V A L S ®

## Certificate of Approval

**Certificate No.:** SAA-190161-EA

**Certificate Holder:** Zhejiang Benyi Electrical Co., Ltd.  
Wenzhou Bridge Industrial Zone,  
Beibaixiang, Yueqing,  
Zhejiang 325603  
P.R. China

**Class Description:** DC Isolator  
**Product Description:** PV Switch-disconnector  
**Brand Name:** ZJBENY  
**Model No.:** BYSS-50  
**Markings:** 1500Vdc (Ie=16A, 35A),  
1200Vdc (Ie=32A, 50A)  
1000Vdc (Ie=50A)  
600Vdc/300Vdc (Ie=50A, 50A)  
Uimp 8kV, Ithe Solar at 40°C: 50A,  
Ithe Solar at 60°C: 50A  
IP66NW Ta: -40 to +85°C DC-PV2  
**Standard:** AS 60947.3:2018  
AS/NZS IEC 60947.1:2015  
**Conditions:** Nil

**Approval Mark:** RCM and SAA-190161-EA

**Date First Registered:** 29 January 2019

**Date of Expiry:** 29 January 2024

*R. A. Hill*


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 20-02-19 190161/1a  
Correction to Markings



A P P R O V A L S ®

## Certificate of Conformity

### \*Addendum\*

**Certificate No.:** SAA-190161-EA

**Date of Issue:** 29 January 2019

**Class Description:** DC Isolator

**Product Description:** PV Switch-disconnector

**Additional Models**

BYSS.1-50

BYSS.2-50

**Description**

Similar to BYSS-50 except for suitable for panel mounting and without enclosure.

Similar to BYSS-50 except for suitable for DIN rail mounting and fixed mounting, and without enclosure.

*R. A. Hill*


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 29-01-19 190161/2