



A P P R O V A L S ®

## Certificate of Conformity

**Certificate No.:** SAA-181241-EA

**Certificate Holder:** Zhejiang Benyi Electrical Co., Ltd.  
Wenzhou Bridge Industrial Zone,  
Beibaixiang, Yueqing,  
Zhejiang 325603  
P.R. China

**Class Description:** DC Isolator  
**Product Description:** PV Switch Disconnecter  
**Brand Name:** ZJBENY  
**Model No.:** BYT-32  
**Markings:** 1200Vdc ( $I_e=13, 32A$ ),  
1000Vdc ( $I_e=13, 32A$ ),  
800Vdc ( $I_e=32, 45A$ ),  
600Vdc ( $I_e=32, 50A$ )  
Ta: -40°C to +85°C, DC-PV2, IP66NW  
**Standard:** AS 60947.3:2018  
AS/NZS IEC 60947.1:2015  
**Conditions:** Nil

**Approval Mark:** SAA-181241-EA or RCM

**Date First Registered:** 6 July 2018

**Date of Expiry:** 6 July 2023

For and on Behalf of  
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 06-07-18 181241/1a  
Correction to Standard



# Certificate of Conformity

## \*Addendum\*

**Certificate No.:** SAA-181241-EA

**Date of Issue:** 6 July 2018

**Class Description:** DC Isolator  
**Product Description:** PV Switch Disconnecter

### Additional Models

BYT-32M1

BYT-32M2

BYT.1-32

BYT.2-32

### Description

Similar to BYT-32 except PV-connector and common MC4.

Similar to BYT-32M1 except PV-connector and common MC4.

Similar to BYT-32 except without enclosure (IP20) and for panel mounting.

Similar to BYT-32 except without enclosure (IP20) and for DIN rail mounting.

For and on Behalf of  
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 06-07-18 181241/2



# Certificate of Conformity

## \*Addendum\*

**Certificate No.:** SAA-181241-EA

**Date of Issue:** 13 November 2018

**Class Description:** DC Isolator

**Product Description:** PV Switch Disconnecter

**General Modification:**

Rating reduced from:

1200Vdc (Ie=13, 32A), 1000Vdc (Ie=13, 32A), 800Vdc (Ie=32, 45A), 600Vdc (Ie=32, 50A); to  
1200Vdc (Ie=9, 32A), 1000Vdc (Ie=9, 32A), 800Vdc (Ie=13, 32A), 600Vdc (Ie=32, 40A), 300Vdc (Ie=32, 45A).

For and on Behalf of  
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 13-11-18 181241/3